



MUNICIPAL CORPORATION CHANDIGARH
Public Health Laboratory at Water Works Sector 39.

TEST - REPORT

Not for legal use

Ref. No. & Date :- No. Nil Dated 03.08.2023
Issued to :- ✓ The Principal,
St. John's High School ,
Sector - 26, Chandigarh. ,
Quantity of sample :- Approximate 1200 ml.
Date of Collection :- 07.08.2023
Client reference :- Sample collected by Laboratory Staff.
Packing of sample :- Sample filled in P.P. and Glass Bottle.
Source of sample :- from School tap of St. John's High School ,
Sector - 26, Chandigarh. ,

S. No.	Examination	Quality Standard	Units	Results
1.	Turbidity	<1.0	N.T.U	0.8
2.	pH	7.0-8.5	----	7.76
3.	Residual Chlorine	0.2 - 0.4	mg/L	0.2
4.	Total Alkalinity (as CaCO ₃)	200	-do-	80
5.	Total Hardness (as CaCO ₃)	200	-do-	72
6.	Chlorides (as Cl)	200	-do-	04
7.	Free & Saline Ammonia	Nil	-do-	Nil
8.	Total Dissolved Solids	500	-do-	124
9.	M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide book/ receipt No.08/2023-24/148150, dated 04.08.2023, Amount Rs.3300/-

Note:- **Water is fit for drinking.**

Lab. No. MCPHL/23/ 3440

Dated:- 09.08.2023

Chemist.
MCPH Laboratory
Chandigarh

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Dated:- _____

Endst No. MCPHL/23/ _____

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh for information please.

Chemist.
MCPH Laboratory
Chandigarh

Sub Divisional Engineer,
M.C.P.H. Sub Division No. 1,
Chandigarh

(In Charge Principal)
St. John's High School
(A Unit of CCBI)
Sector 26,
Chandigarh-160019