



MUNICIPAL CORPORATION CHANDIGARH  
Public Health Laboratory at Water Works Sector 39.

TEST – REPORT

Not for legal use

Ref. No. & Date :- No. Nil Dated 03.08.2023  
Issued to :-  The Principal,  
St. John's High School ,  
Sector - 26, Chandigarh. ,  
Quantity of sample :- Approximate 1200 ml.  
Date of Collection :- 07.08.2023  
Client reference :- Sample collected by Laboratory Staff.  
Packing of sample :- Sample filled in P.P. and Glass Bottle.  
Source of sample :- from School tap of St. John's High School ,  
Sector - 26, Chandigarh. ,

S. No.	Examination	Quality Standard	Units	Results
1.	Turbidity	<1.0	N.T.U	0.8
2.	pH	7.0-8.5	----	7.76
3.	Residual Chlorine	0.2 – 0.4	mg/L	0.2
4.	Total Alkalinity (as CaCO <sub>3</sub> )	200	-do-	80
5.	Total Hardness (as CaCO <sub>3</sub> )	200	-do-	72
6.	Chlorides (as Cl)	200	-do-	04
7.	Free & Saline Ammonia	Nil	-do-	Nil
8.	Total Dissolved Solids	500	-do-	124
9.	M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide book/ receipt No.08/2023-24/148150, dated 04.08.2023, Amount Rs.3300/-

**Note:- Water is fit for drinking.**

Lab. No. MCPHL/23/ 3440

Dated:-09.08.2023

Chemist.  
MCPH Laboratory  
Chandigarh

Sub Divisional Engineer,  
M.C.P.H. Sub Division No.1,  
Chandigarh.

Dated:- \_\_\_\_\_

Endst No. MCPHL/23/ \_\_\_\_\_

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh for information please.

Chemist.  
MCPH Laboratory  
Chandigarh

Sub Divisional Engineer,  
M.C.P.H. Sub Division No. 1,  
Chandigarh